




Pro-Fit Parallel Ball Valves

Lever Handles, Brass


- Full bore
- Nickel plated
- BS EN331
- Screwed BSPP Female x Female
- PN25 (1/4" - 4")

Temperature Ranges:
-20°C to +130°C



No.	∅	∅a	∅b	A	B	C	D	CH	G	WT
100ps-025	10	22.7	24	83	38	45.6	12.2	21	1/4	
100ps-050	10	22.7	24	83	38	45.6	12.2	21	3/8	
100ps-075	14.5	29	31.5	95.5	44	56.2	16	24.92	1/2	
100ps-100	19	33.5	36.5	115.5	46.5	68	16	31.7	3/4	
100ps-125	24.5	41.5	43.7	115.75	53.5	78	20.5	37.5	1	
100ps-150	31.5	52.6	56.5	131	67	90	20.5	46.35	1.1/4	
100ps-175	39.5	64.1	67.5	163	72	102	20.5	52.5	1.1/2	
100ps-200	49.5	78.5	82	163	77	123	22.8	65.05	2	
100ps-225	62	99.7	103.5	247	115	146	28.8	81.7	2.1/2	
100ps-250	73	115.5	119.5	247	121	170	28.8	95.53	3	
100ps-275	90	142	147	247	135	200	36.6	120.75	4	

No.	Part Name	Materials	Treatment
1	Body	Brass	Nickel plated
2	Body End	Brass	Nickel plated
3	Nut	Steel	Zinc plated
4	Stem	Brass	
5	Handle	Steel	PVC-Plastic coated
6	Packing Nut	Brass	
7	Stem Seat	PTFE	
8	Seat	PTFE	
9	Ball	Brass	Chrome plated




Remarks: Same dimension for body and the temperature range. Only difference on handle.


Butterfly Handles, Brass

- Full bore
- Nickel plated
- BS EN331
- Screwed BSPP Female x Female
- PN25 (1/4" - 1")

Temperature Ranges:
-20°C to +130°C



Pressure & Temperature



No.	Part Name	Materials	Treatment
1	Body	Brass	Nickel plated
2	Body End	Brass	Nickel plated
3	Seat	PTFE	
4	Ball	Brass	Chrome plated
5	Stem	Brass	
6	Stem Seat	PTFE	
7	Packing Nut	Brass	
8	Handle		
9	Nut	Steel	Zinc plated



CERTIFICATION MARK

This certifies that

TESLA UK LTD.

has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations and Scottish Water Byelaws.

GB/BVL, GB/BVL, BVL & BLH SPHERICAL VALVES

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

November 2021

1611070

Certificate No.

Handwritten signature of J. Funnal in black ink.

Secretary

Handwritten signature of K. Hewsey in black ink.

Chairman, Product Assessment Group