DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

CERTIFICATE

Certificate holder	**Ape Raccorderie S.r.l.** **Via Gozzano** **825068 Sarezzo BS** **ITALY**
Product	Plastic piping and multilayer piping systems for warm water floor heating systems and radiator connecting systems
Type, Model	APE Multilayer + Serie AP
Testing basis	DIN 4726:2017-10 DIN EN ISO 21003-2:2011-07 DIN EN ISO 21003-3:2008-11 DIN EN ISO 21003-5:2008-11 Certification Scheme Plastic piping and multilayer piping sytems for warm water floor heating systems and radiator connecting systems (2019-03)
Mark of conformity	DIN Geprüft
Registration No.	3V370 MVR (M)
Valid until	2028-07-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2023-05-12

Dipl.-Phys. Carlo Seiser
Head of Certification Body

GESELLSCHAFT FÜR KONFORMITÄTSBEWERTUNG MBH DIN CERTCO

DIN

DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

ANNEX

Certificate

3V370 MVR (M) dated 2023-05-12

Technical Data

Pipe:
- Name of manufacturer: APE Raccorderie s.r.l.
- Production plant: Sarezzo, Italy
- Material designation: PE-Xb/Al/PE-Xb
- Nominal-outside diameter x nominal thickness(mm): 16 x 2.0; 20 x 2.0; 26 x 3.0; 32 x 3.0
- Application class and operating pressure: Class 5 / 8 bar

Fitting/Connector:
- Name of the manufacturer: APE Raccorderie s.r.l.
- Production plant: Sarezzo, Italy
- Type of fitting: Press connectors
- Material designation: Metal
- Type designation: Mech. Metal connector for composite pipes (M-MV)
- Model: AP 101 DRITTO MASCHIO, AP 102 DRITTO FEMMINA, AP 103 DRITTO INTERMEDIO UGUALE, AP 103 DRITTO RIDOTTO, AP 131 TEE UGUALE, AP 131 TEE RIDOTTO, AP 132 TEE FEMMINA, AP 133 TEE MASCHIO, AP 151 GOMITO INTERMEDIO, AP 152 GOMITO FEMMINA, AP 153 GOMITO MASCHIO, AP 154 GOMITO CON FLANGIA, AP 154L GOMITO CON FLANGIA CORTA, AP 154D GOMITO DOPPIO CON FLANGIA, AP 54A TERMINALE SINGOLO, AP 54B TERMINALE DOPPIO A 90, AP 54C TERMINALE DOPIO A 165, AP 185 RACCORDO CON GIRELLO

Testing laboratory/ Inspection body

Kiwa Nederland B.V.
Wilmersdorf 50
7327 AC APELDORN
NETHERLANDS

Test report(s)

Alteration/Extension
180200972 – A dated 2019-12-19
191002238 – A dated 2020-05-26
180200972 (LC15543) dated 2019-11-22
180200972 (LC15544) dated 2019-11-22

Surveillance 2021
Inspection report dated 2021-09-29
LC 20167 dated 2021-06-30
LC 20168 dated 2021-06-08
LC 20169 dated 2021-06-23
LC 20172 dated 2021-07-19

ANNEX

Certificate 3V370 MVR (M) dated 2023-05-12

LC 20408 dated 2021-08-26

Surveillance 2022
Inspection report dated 2022-03-23
LC 20916 dated 2022-01-12
LC 20917 dated 2021-12-20
LC 20910 dated 2022-01-25
LC 20915 dated 2022-03-23
LC 20914 dated 2022-03-23
LC 20909 dated 2022-01-21
Inspection report dated 2022-05-19
LC 21708 dated 2022-07-13
LC 21706 dated 2022-09-02
LC 21705 dated 2022-09-15
LC 21709 dated 2022-06-30
LC 21621 dated 2022-09-02
P000032995-TRA-rev1 dated 2022-09-13