

OPTIONS

Flush Volume

- 0.5 gpf (1.9 Lpf) (0.5)
- 1.0 gpf (3.8 Lpf) (1.0)
- 0.125 gpf (0.5 Lpf) (0.125)
- 1.5 gpf (5.7 Lpf) (1.5)
- 0.25 gpf (0.9 Lpf) (0.25)

Water Efficiency

- High Efficiency
- Low Consumption
- Water Saver

Bypass

- Dual-Filtered Fixed Bypass Diaphragm
- Dual-Filtered Bypass

Override

- Less (L/OR)
- Electrical
- True Mechanical (TMO)

Wall Box

- With (W/BOX)
- Small (SWB)

Control Stop

- Less (L/STOP)

Compliances & Certifications

- ADA Compliant
- BAA Compliant
- BABAA Compliant
- UL Certified
- UPC Certified
- cUPC Certified
- Satisfies LEED Credits
- cUPC Green Certified
- BREEAM Water Credit
- Green Globes Water Credit

NOTES

For product line drawings, [view model-specific spec sheets](#).

All information contained within this document subject to change without notice.



DESCRIPTION

Sloan® Concealed Sensor Hardwired Urinal Flushometer

FEATURES

- Flush volumes start as low as 1.0 gpf/3.8 Lpf
- Water conservation is aided by the ADA-compliant, non-hold-open handle, which prevents urinal from exceeding intended flush volume
- Low-consumption flush accuracy also enhances water efficiency
- Durability is facilitated with high copper, low zinc brass castings for dezincification resistance
- Adjustable tailpiece to accommodate different height requirements
- High chloramine resistant PERMEX synthetic rubber diaphragm with Linear Filtered Bypass and Vortex Cleansing Action
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Semi-Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037.

DOWNLOADS

- [Sloan Concealed Installation Instructions](#)
- [Sloan 152/195 ESS TMO Installation Instructions](#)
- [Sloan 152/140/153/195 ESS TMO SWB Installation Instructions](#)
- [Sloan/Regal ESS Repair and Maintenance Guide](#)
- [Optima ESS Repair and Maintenance Guide](#)
- [Flush Connections Flanges Repair and Maintenance Guide](#)
- [Tail Piece Repair and Maintenance Guide](#)

Sloan 10500 Seymour Ave, Franklin Park, IL 60131

Phone: 800.982.5839 • Fax: 800.447.8329 • sloan.com

- [Control Stop Repair and Maintenance Guide](#)
- [Optima ESS TMO Exposed Repair and Maintenance Guide](#)
- [Additional Downloads](#)

VIDEOS

-  [ESS Flushometer](#)