



Urinal & Flushometer Combo

WEUS-7400.3002

Product description

Standard, SU-7409 Urinal and SLOAN 186 ESS Flushometer.

Compliances & Certifications



(BAA Compliant, BREEAM Water Credit, Green Globes Water, LEED Water, Satisfies LEED Credits)

Code 74003002

Downloads

- [Sloan _ Regal ESS TMO Installation Instructions.pdf](#)
- [Model SU-7409-7419 Urinal Installation Instructions.pdf](#)
- [Additional Downloads](#)

Videos

- [Sloan – Company Overview](#)

Details

- Flush Volume: 0.125 gpf (0.5 lpf)

Features

- Flush volumes start as low as 1.0 gpf/3.8 Lpf
- Water conservation is aided by the ADA-compliant, non-hold-open handle, which prevents urinal from exceeding intended flush volume
- Flush accuracy is controlled by CID™ technology, also enhancing water efficiency
- Integrity of the product is maintained with the vandal-resistant stop cap
- Durability is facilitated with high copper, low zinc brass castings for dezincification resistance
- Adjustable tailpiece to accommodate different height requirements
- High chloramine resistant PERMEX® Synthetic Rubber Diaphragm with Linear Filtered Bypass and Vortex Cleansing Action
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Semi-Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037
- Designed to maximize and complement Sloan flushometers
- Small size and fully enclosed trapway provide attractive design
- Thorough washdown flushing action
- Vandal resistant stainless steel strainer included
- IAPMO certified to meet or exceed ASME A112.19.2 standards
- Water Sense listed by EPA that qualifies for most rebate programs
- Meets ADA guidelines and ANSI A117.1 requirements when installed accordingly

Components



- Flushometer: Code 3772645
- Urinal: Code 1107409

Warranty

[View Warranty Information](#)

Notes

All information contained within this document subject to change without notice.



NOTE: ADA urinal rim height requirements allow all heights 17" and below. Sloan strongly recommends roughing in the drain to achieve a 16½" rim height or less to ensure compliance.