

#### **OPTIONS**

#### Flush Volume

3.5 gpf (13.2 Lpf) (3.5)

1.6 gpf (6.0 Lpf) (1.6)

## **Water Efficiency**

Water Saver

Low Consumption

### **L Dimension**

6 3/4" (171mm) (6-3/4-LDIM)

4 3/4" (121mm) (4-3/4-LDIM)

8 3/4" (222mm) (8-3/4-LDIM)

3 3/4" (95mm) (3-3/4-LDIM)

2 3/4" (70mm) (2-3/4-LDIM)

5 3/4" (146mm) (5-3/4-LDIM)

10 3/4" (273mm) (10-3/4-LDIM)

11 3/4" (298mm) (11-3/4-LDIM)

9 <sup>3</sup>/<sub>4</sub>" (248mm) (9-3/4-LDIM)

#### **Wall Box**

Standard (not included, order separately)

#### Handle

Metal Oscillating ()

#### **Push Button**

3" Metal Oscillating (L3)

### **Control Stop**

1" Straight (E)

Ground Joint (GJ)

### **Vacuum Breaker**

Less (XYV)

# **Special Features**

Whitworth Thread (WWT)

# **Compliances & Certifications**

**BAA Compliant** 

**BABAA** Compliant

**UPC** Certified

### NOTES

For product line drawings, view model-specific spec sheets.

All information contained within this document subject to change without notice.



### **DESCRIPTION**

Naval Concealed Manual Water Closet Flushometer

#### **FEATURES**

- Non-hold-open oscillating handle, Bak-Chek™ control stop and self-cleaning Xpelor Metering By-Pass ensure reliable operation and accurate flush delivery
- Available with adjustable or ground joint supply stop (ground joint recommended for salt water applications)
- Factory set flush volume of either 1.6 gpf/6.0 Lpf or 3.5 gpf/13.2 Lpf with adjustment range of 1.5 gpf/5.7 Lpf to 7.0 gpf/26.5 Lpf
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037.

# **DOWNLOADS**

- Naval Piston Type Exposed Installation Instructions
- Naval Repair and Maintenance Guide
- Control Stop Repair and Maintenance Guide
- Flush Connections Flanges Repair and Maintenance Guide
- Tail Piece Repair and Maintenance Guide
- Concealed Flushometers Repair and Maintenance Guide
- Additional Downloads

Phone: 800.982.5839 • Fax: 800.447.8329 • sloan.com