



Water Closet & Flushometer Combo

WETS-2000.1015-BPL

Product description

Standard, ST-2009 Water Closet and REGAL 111 Flushometer.

Compliances & Certifications

















(BREEAM Materials Credit, BREEAM Water Credit, CalGreen Compliant, CEC Compliant, cUPC Certified, cUPC Certified, cUPC Green Certified, EPD, Green Globes Credit, Green Globes Water, HPD, IAPMO, LEED Credit, LEED HPD, LEED Water, Satisfies LEED Credits, EPA WaterSense Listed, WELL Building Standard)

Code 20001015

Downloads

- MET Top Spud Installation Instructions.pdf
- Regal XL Exposed Installation Instructions.pdf
- Regal Flushometers Repair and Maintenance Guide.pdf
- SS:ST:SU:WETS:WEUS Fixtures Repair and Maintenance Guide.pdf
- Fixture Brochure.pdf
- Flushometers Brochure.pdf
- Additional Downloads

Videos

Sloan – Company Overview

Details

• Flush Volume: 1.1-1.6 gpf (4.2 - 6.0 lpf)

Features

- Flush volumes start as low as 1.6 gpf/6.0 Lpf to meet waterefficiency objectives
- Water conservation is aided by the ADA-compliant, non-holdopen handle, which prevents toilet from exceeding intended flush volume
- Low Consumption flush accuracy controlled by Para-Flo™
 Technology
- · Integrity of the product is maintained with control stop plug
- Durability is facilitated with high copper, low zinc brass castings for dezincification resistance
- · Adjustable tailpiece
- Valve body, Cover, Tailpiece and Control Stop shall be in compliance with ASTM Alloy Classification for Semi-Red Brass
- Valve shall be in compliance to the applicable sections of ASSE 1037
- · Designed to maximize and complement Sloan flushometers
- · Universal model works with Sloan flushometers from 1.1 to 1.6 gpf
- · Durable, hygienic vitreous china construction with elongated rim
- Syphonjet flushing achieves 1000g Map Scores when used with Sloan flushometers
- IAPMO certified to meet or exceed ASME A112.19.2 standards
- WaterSense compliant when used with a WaterSense compliant flushometer

Components

Flushometer: Code 3080050Water Closet: Code 2102009

Warranty

View Warranty Information

Notes

All information contained within this document subject to change without notice.

Static load tested according to the procedure outlined in Section 6.7 of ASME A112.19.2. Not recommended for bariatric use.





